



**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**  
(Wholly owned Government of Karnataka undertaking)

No.: SEE/BCS/EE(O)/AEE-1/NOC-26/11-12/  
Encl: 12637-39

Superintending Engineer, C, O&M, Bangalore  
South Circle, BESCOM No. 14/3, 3rd Floor,  
Maharshi Aravinda Bhavan, Nrupathunga Road,  
Bangalore-560 001.

**M/s Krishna E Campus,  
Sy No. 46/1, 47/1 & 48/1,  
Ambalipura Village,  
Sarjapura Road,  
Bangalore.**  
Sir,

17 SEP 2011

**Sub:-** Issue of NOC for arranging power supply to an extent of **1850KVA** to the proposed Residential & Commercial Building in favour of M/s Krishna E Campus, Sy No. 46/1, 47/1 & 48/1, Ambalipura Village, Sarjapura Road, Bangalore.

**Ref:-** Ltr No. EE(E)/HSRD/AEE(O)/JE-1/3539 dtd 16.09.11.

\*\*\*\*\*

With reference to the above, 'No Objection Certificate' from BCS, BESCOM is hereby issued for arranging power supply to the proposed **Residential & Commercial Building** to an extent of **1850KVA** at Sy No. 46/1, 47/1 & 48/1, Ambalipura Village, Sarjapura Road, Bangalore, subject to the following conditions:

1. Power supply to your proposed **Residential & Commercial Building** will be arranged with the following arrangements.

**Proposals: -**

**Regular Source:**

- a. To provide the new 11KV feeder is proposed from Shobha MUSS by laying 3x400 Sq.mm XLPE HTUG cable to a total distance of about 1.5km under self execution.
- b. To provide one RMU of 2OD + 1VL inside the applicant's premises.

**Alternate Source:**

- c. To provide from F-17 feeder of HSR MUSS.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **self execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

...2)

3. If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
4. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said **Residential & Commercial Building** /various buildings at the above address, all rules as per KERC Electricity Supply and Distribution code shall be observed.
6. Power supply shall be arranged to the said M.S. Building based on the provisions of regulations of BESOCM applicable at that time.
7. This "NOC" is issued only for the purpose of obtaining sanction plan for **Residential & Commercial Building** from BDA/BMP/Competent authorities and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
8. The approximate load requirement of the above **Residential & Commercial Building** is **1850KVA.**
9. If the requisitioned load is 4000KVA to 7500KVA, land measuring 50mtr x 60mtrs shall be handed over to KPTCL / BESCOM at free of cost for establishing 66/11KV substation.
10. If the requisitioned load is more than 7500KVA, the applicant has to establish 66/11KV substation inside the premises under self execution.
11. This **NOC** is valid for a period of **Two year** from the date of issue.

Yours faithfully,



**Superintending Engineer (El.),  
Bangalore Circle (South), BESCOM,  
Bangalore**