



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(WHOLLY OWNED GOVERNMENT OF KARNATAKA UNDERTAKING)

NO:SEE/BEC-160/AEE-1/12-13/ 4236-38

Enc:

Phone/Fax-080-22863422

Email Id:see.eastcircle@gmail.com

Office of the
Superintending Engineer (EI)
East Circle, # 12, Curve Circle,
Tasker Town, Shivajinagar,
Bangalore -560051

Date :

19 JUN 2012

Sri Nirmal Kumar and others,
GPA M/s Puravankara Projects Ltd.,
No. 130/1, Ulsoor Road,
Bangalore.

Sir,

Sub: Issue of NOC for arranging power supply to an extent of 1290KVA for Residential in favour of Sri Nirmal Kumar and others, GPA M/s Puravankara Projects Ltd., at No.236/1-1, 236/2-1, 236/3-1, 236/4-2, 236/4-3, 236/4-4(P), 79/1-3, 79/1-4, 79/1-5, 236/4, Magadi main road in W-3 sub-division-reg.,

Ref: Executive Engineer(EI),Vidhanasoudha division letter no. EEE/EEE/AEE(O)/AET-2/12-13/1278-79 dt.2.06.12

With reference to the above, 'No Objection Certificate' from, BESCOM Bangalore East circle is hereby issued for 1290 KVA for Residential building in favor of Sri Nirmal Kumar and others, GPA M/s Puravankara Projects Ltd., at No.236/1-1, 236/2-1, 236/3-1, 236/4-2, 236/4-3, 236/4-4(P), 79/1-3, 79/1-4, 79/1-5, 236/4, Magadi main road in W-3 sub-division, as per KERC (Recovery of Expenditure for supply of Electricity) Regulations 2004 which is in force and its amendments from time to time subject to the following conditions:

Power supply to your Residential & Commercial building will be arranged with the following arrangements.


Proposals:-

Regular Source:

1. Drawing express feeder from Telecom Station using 3x400sq.mm HT cable to the applicant premises to a distance of 2km with inter posing ODs with station matching breaker.
2. Providing 2OD+2VL RMU with 3x500 KVA transformers inside the applicant premises for the Residential loads.

- You have to develop the above infrastructure including the cost of 11KV lines etc., as mentioned above on self-execution basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
- If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
- If any installation existing in the said premises the same shall be surrendered by clearing all arrears before taking up infrastructure work.
- While applying for power supply to the said Residential building at the above address, all rules as per KERC Electricity Supply and Distribution code in force shall be observed.
- Power supply shall be arranged to the said Residential building based on the provisions of regulations of BESCOM which are applicable at that time.
- This "NOC" is issued only for the purpose of obtaining sanction plan for Residential building from BDA/BMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
- The Approximate load requirement of the above Residential building is 1290KVA.
- This NOC is valid for a period of One year from the date of issue.

Yours faithfully



(G. Sheela)
Superintending Engineer (El)
Bangalore East Circle.