

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**

(Wholly owned Government of Karnataka undertaking)

9

No.: EE/HSR/ AEE (O)/AE-1/14-15

Encl:

Office Of

Executive Engineer Elec(C,O&M)

7276-77 HSR Layout Division, BESCOM,
17th cross, 24th main, HSR 2nd sector,
Bangalore-560102.

Date: 3 FEB 2015

To,

Sri. G.R.Kupendra Guptha,
GPA M/s Sumo Properties Rep by Meda
Sreedhar, K.No. 398/245/2/48/7,
Sy No. 48/7, Kudlu Village,
Sarjapura Hobli, Bangalore.,

Sir,

Sub:- Issue of NOC to the proposed Residential building for arranging power supply to an extent of 800KW (945KVA) in favour of Sri. G.R.Kupendra Guptha, GPA M/s Sumo Properties Rep by Meda Sreedhar, K.No. 398/245/2/ 48/7, Sy No. 48/7 Kudlu Village, Sarjapura Hobli, Bangalore., of S-8 Sub Division.

Ref:- 1) AEE/S8/AET/ 2969 dt: 06.02.15 of the Assistant Executive Engineer Ele, S-8 Sub-Division, BESCOM, Bangalore.

2) Applicant ltr.Dt: 12.01.15

With reference to the above, '**No Objection Certificate**' is hereby issued for Residential building (3Block) for arranging power supply to an extent of 800KW (945KVA) in favour of Sri. G.R.Kupendra Guptha, GPA M/s Sumo Properties Rep by Meda Sreedhar, K.No. 398/245/2/48/7, Sy No. 48/7 Kudlu Village, Sarjapura Hobli, Bangalore., of S-8 Sub Division, subject to the following conditions:

Proposals:-**Regular Source: -**

a.) The Proposed load is feasible only after the augmentation of power transformers 2x20MVA by 2x31.5MVA at Naganathpura MUSS.

1) It is proposed to draw new 11KV line from Naganathpura MUSS by laying 3X400Sqmm UG cable to the applicant premises and also proposed to provide intermediate OD's at regular intervals.

2) It is proposed to provide 3way RMU (2OD+VL) inside the premises.

Power supply to your proposed Residential apartment of 3 block having land area 80586 Sqft will be arranged as per the prevailing KERC norms at the time of availing power supply.

1. BESCOM will not be held responsible for any liability arising from the issue of NOC.