ಭವಿಕಂ



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No: CEE/BMAZ/SEE(O)/AEE-4/F-245

Encl:

2999-3001

Office Of The Chief Engineer Ele., [C,O&M], BMAZ, No. 14/3, 3rd Floor, Maharshi Aravinda Bhavan,

Nrupatunga Road, Bangalore-560001. Date: 11 9 JUN 2010

To. M/s. Palladium Construction & Platinum Hospitality Services Pvt. Ltd., No.1 Industrial suburgward No.14 Nagapur, Dr. Rajkumar Road, Bangalore 10.

Sir,

Issue of No Objection Letter (NOC) for arranging power supply to an extent of 18 MVA on EHT basis for the proposed M.S. Buliding in favour of M/s. Palladium Construction & Platinum Hospitality Services Pvt. Ltd., No.1, Industrial Suburb, Ward No.14, Dr. Rajkumar Road, Bangalore 10.

With reference to the above subject, approval is hereby accorded for No Objection Certificate (NOC) for the 'proposed M.S. Buliding to an extent of 18 MVA on EHT basis in favour of M/s Palladium Construction & Platinum Services Pvt. Ltd., No.1, Industrial suburb, Ward No.14, Nagapur, Dr. Rajkumar Road, Bangalore 10 in N-1 Sub-Division of North Division subject to the following conditions:-

- Regular Source:- To draw a new 66 KV line from the exsiting 220/66 Peenya receiving station upto the consumer premises and to establish a new 66/11 Sub-station in his premises under self execution.
- Alternate Source:- To tap 66 KV line from the exsisting MUSS at Nandini layout (01X 31.5 MVA + 01X20 MVA, Peak load 24.8 MW) under self execution.
- + Incase the consumer proposed Jad exceeds 20000 KVA in future, the consumer has to obtain power supply on 220 KV basis only.
- * The Validity of this 'NOC' is for a period of Twenty Four Months only from the date of this letter.
- BESCOM will not be held responsible for any liability arising from the issue of NOC.
- If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at the applicants cost.

-BOATT MANAGE AND A BALLONG SA

- While applying for power supply to the said premises, all rules as per KERC electricity Supply and Distribution code shall be observed.
- Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
- This 'NOC' is issued only for the purpose of obtaining sanction for MS Building plan from BDA/BBMP/Competent authorities and is not commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
- A commitment letter for carrying out the above works under self execution shall be furnished by you.
- All the works of developing infrastructure shall be carried out by the applicant under self execution through the government class-I electrical contractor under the guidence of BESCOM/KPTCL duly observing the BESCOM/KPTCL formalities.
- * This NOC is confirmed to a maximum load of 18MVA only.

Yours faithfully,

Chief Engineer Ele., (C,O&M), BMAZ BESCOM.

Copy to:

- 1. The Superintending Engineer (El.,), (C,O&M), Bangalore North Circle, BESCOM, Bangalore
- 2. The Executive Engineer (El.,), (C,O&M), North Division, BESCOM, Bangalore along with the entire file for information.
- 3. AEE-4.
- 4. MF/F-244.