

ಬೆವಿಕಂ



Bangalore Electricity Supply Company Limited

(Wholly owned Government of Karnataka Undertaking)

Ph : 2226 3176
2226 0803
2226 2551
(Fax) : 2220 2170

No.: CGM/BMAZ/DGM/AGM-2/F-246/



17732-35

Office of the Chief General Manager, Ele.,
(Commercial, Operation & Maintenance),
Bangalore Metropolitan Area Zone,
P.B. No. 5163, K.R. Circle,
Bangalore-560 001.

Date : 31/03/06

M/s. Davanam Constructions Pvt. Ltd.,
C/o Shobha developers Pvt. Ltd.,
E-106, Sunrise chambers ,
22 Ulsoor road,
Bangalore 560042.

Sir,

Sub: Issue of NOC for the proposed M.S. Building at
Sy. No. 19/2 Gopalapuram Near Minerva Mill compound
Mysore Deviation road, Bangalore

Ref: 1. BESCOM/GM(T)/BC-22/F-702(23)/05-06/19762-65.
dated; 25.3.06.


With reference to the above, 'No Objection Certificate' from BESCOM is hereby issued for the proposed M.S. Building at Sy. No. 19/2 Gopalapuram near Minerva Mill compound Mysore Deviation road, Bangalore subject to the following conditions:

1. Power supply to your proposed M.S. Building will be arranged from new 66/11 Kv MUSS within the applicants premises and has to give a land measuring 4000 sq.m at free of cost to KPTCL to establish sub- station by the side of the consumer station.
2. You have to meet the cost of developing infrastructure including the cost of 11KV lines etc., as mentioned above on **SELF-EXECUTION** basis through a class-I LEC by paying necessary supervision charges to BESCOM and KPTCL.
3. While applying for power supply to the said MS Building at the above address, all rules as per KERC ES&D Code shall be observed.
4. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations in force of BESCOM at that time.
5. This 'NOC' is issued only for the purpose of obtaining sanction for the MS Building plan from BDA / BMP / BMIC / Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.

.....Contd 2

6. The approximate load requirement of the above MS Building is
16.5 MW

Yours faithfully,

A handwritten signature in dark ink, appearing to be 'WJ' or similar, written over the typed name.

Chief General Manager, Ele.,
(C,O&M), BMAZ, BESCOM.