



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(WHOLLY OWNED GOVERNMENT OF KARNATAKA UNDERTAKING)

NO:SEE/BEC-684/AEE-1/12-13/ 10037-39

Enc:

Phone/Fax-080-22863422

Email Id:see.eastcircle@gmail.com

Office of the
Superintending Engineer (El)
East Circle, # 12, Curve Circle,
Tasker Town, Shivajianagar,
Bangalore -560051

Date : 19 NOV 2012

To,
Sri.Abraham Ninan,
S/O Sri.N.G.Ninan,
Nadvallil,1st Main,
4th Block,HBR L/O,
Kalyanagar Post,
Bengaluru-43.

Sir,

Sub: Issue of NOC for arranging power supply to an extent of 1750 KVA for Residential in favor of Sri.Abraham Ninan,S/O Sri.N.G.Ninan, at Sy.No.21, K.Narayanapura, Bangalore ,in E-9 sub-division-reg.,

Ref: Executive Engineer(EI), Shivajinagar division letter no. EEE/SND/AEE(O)/ AE-T/6327 dt.25.10.122.Superintending Engineer Ele., BSC, NOC

With reference to the above, 'No Objection Certificate' from, BESCOM Bangalore East circle is hereby issued for arranging power supply to an extent of 1750 KVA for Residential in favor of Sri.Abraham Ninan,S/O Sri.N.G.Ninan, at Sy.No.21, K.Narayanapura, Bangalore as per KERC (Recovery of Expenditure for supply of Electricity) Regulations 2004 which is in force and its amendments from time to time subject to the following conditions:

Power supply to your Residential building will be arranged with the following arrangements.

Proposals:-

Regular Source:

1. Drawing express feeder from HBR Station using 3x400sq.mm HT cable to the applicant premises to a distance of 9.5km with inter posing OD's and station matching breaker.
2. Providing 2OD+34L RMU with 3x500 KVA & 1x250KVA transformers inside the applicant premises for the Residential loads.


Alternate Source:

1. Drawing express feeder from Banasawadi Station using 3x400sq.mm HT cable to the applicant premises to a distance of 9.0km with inter posing OD's and station matching breaker.

....PTO.,

- You have to develop the above infrastructure including the cost of 11KV lines etc., as mentioned above on self-execution basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
- If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
- If any installation existing in the said premises the same shall be surrendered by clearing all arrears before taking up infrastructure work.
- While applying for power supply to the said Residential & Commercial building at the above address, all rules as per KERC Electricity Supply and Distribution code in force shall be observed.
- Power supply shall be arranged to the said Residential building based on the provisions of regulations of BESCOM which are applicable at that time.
- This "NOC" is issued only for the purpose of obtaining sanction plan for Residential building from BDA/BMP/Competent authorities and is not a commitment for power sanction from BESCOM, Power supply will be sanctioned when applied for, subject to feasibility at that time.
- The Approximate load requirement of the above Residential building is 1750KVA.
- This NOC is valid for a period of One year from the date of issue.

Yours faithfully



(G. Sheela)
Superintending Engineer (El)
Bangalore East Circle.