

ಬೆಂಗಳೂರು



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No.: EE/HSRD/JE-1/ 748
Encl:

Office Of
Executive Engineer Elec(C,O&M)
HSR Layout Division, BESCOM,
17th cross, 24th main, HSR 2nd sector,
Bangalore-560102.

Date: 4 MAY 2012

Sri T.Venkataswamy Reddy,
No. 59, Doddakanahalli Village,
Varthur Hobli, Bangalore.

Sir,

Sub:- Issue of NOC to the proposed **Residential Apartment** for arranging power supply to an extent of **1000KVA (848KW)** in favour of Sri.T.Venkataswamy Reddy, Sy.No:59, Doddakanahalli Village, Varthur Hobli, Bangalore of S-11 Sub-division.

- Ref:- 1) AEE(E)/S11/AE(T)/318 dt:23.04.12 of the Assistant Executive Engineer Ele, HSR Layout, S-11 Sub-Division, BESCOM, Bangalore.
2) Applicant ltr.Dt:23.01.12

With reference to the above, **'No Objection Certificate' from EE, BESCOM** is hereby issued for issue of NOC to the proposed **Residential Apartment** for arranging power supply to an extent of **1000KVA (848KW)** in favour of Sri.T.Venkataswamy Reddy, Sy.No:59, Doddakanahalli Village, Varthur Hobli, Bangalore of S-11 Sub-division Subject to the following conditions:

1. Power supply to be arranged from Regular source from 66/11KV **Dommasandra MUSS.**

Regular Source: -

- a) It is proposed to extend 3X400Sqmm UG Cable to a distance of 2.8KM from F3 feeder of Dommasandra MUSS.
- b) It is proposed to provide 1 no of 2OD + 2VL RMU inside applicant premises under self execution.
- c) It is proposed to provide one Interposing OD.
- d) It is proposed to install 2X500KVA DTC inside the premises.

Alternate Source: -

- a) It is proposed from RMZ MUSS.

2. BESCOM will not be held responsible for any liability arising from the issue of NOC.

4. If any installations existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said Residential apartment at the above address all rules as per KERC Electricity supply and distribution code shall be observed.
6. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCO at that time.
7. The necessary infrastructure for arranging power supply to the said premises shall be developed under self execution by the applicant.
8. This 'NOC' is issued only for the purpose of obtaining sanction for the Residential Apartment plan from BDA/BBMP/BMIC/Competent authorities and is not a commitment for power sanction from BESCO. Power supply will be sanctioned when applied for, subject to feasibility at that time.
9. The necessary infrastructure for arranging power supply to the said premises shall be developed under self execution through class-I LEC.
10. For Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat.
11. As per the above, if there is no sufficient space to provide solar water heaters block of Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat for total no. of flats on the top of the blocks.
12. Validity of this NOC is for 2(Two) years only from the date of this letter.

Yours faithfully,


Executive Engineer (Ele)
C, O&M, HSR Layout Division,
BESCO, Bangalore.