



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.: SEE/BCS/EE(O)/AEE-2/NOC-01/12-13/
Encl: 3-0-32

Superintending Engineer, C, O&M, Bangalore
South Circle, BESCOM No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nr. pathunga
Road, Bangalore-560 002.

To
Sri. K. Vishwanath,
Sy No. 60/2,
Doddakanahalli Village,
Bangalore.
Sir,

11 APR 2012

Sub:- Issue of NOC for arranging power supply to an extent of 1653KW to the proposed Residential Apartment in favour of Sri. K. Vishwanath, Sy No. 60/2, Doddakanahalli Village, Bangalore.
Ref:- Ltr No. EE(E)/HSRD/AEE(O)/JE-1/9045-46 dt: 31.03.2012.

With reference to the above, 'No Objection Certificate' from BCS, BESCOM is hereby issued for arranging power supply to the proposed Residential Apartment to an extent of 1653KW at Sy No. 60/2, Doddakanahalli Village, Bangalore, subject to the following conditions:

1. Power supply to your proposed Residential Apartment will be arranged with the following arrangements.

Regular Source:

- a. To evacuate the new 11KV feeder from Sobha MUSS by laying 3x400 Sq.mm XLPE UG cable to a total distance of about 2.5km.
- b. To provide 1 No. of 2OD+1VL RMU inside the applicant premises under self execution.
- c. To provide 2Nos. of intermediate OD's.

Alternate Source:

- d. To lay 3x400Sq.mm HTUG cable to a distance of about 3.5km from F-12 feeder of HSR MUSS.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on self execution basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

..2)