



**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**  
(Wholly owned Government of Karnataka undertaking)

No.:EEE/JD/AEE(O)/JE-1/NOC-02/13-14  
Encl:

7232

Executive Engineer, C, O&M,  
Jayanagar Division, BESCOM  
BSK 2nd Stage,  
Bangalore-560 001.  
Date:

128 OCT 2013

To,  
Sri.M.S.Sridhar, M/s Shravanee Sumo,  
No.20, 39<sup>th</sup> Cross, 8<sup>th</sup> Block, Jayanagar,  
Bangalore.  
Sir,

**Sub:-** Issue of NOC to an extent of 250KVA for proposed Building in favour of Sri. M.S.Sridhar, M/s Shravanee Sumo, No.20, 39<sup>th</sup> Cross, 8<sup>th</sup> Block, Jayanagar, Bangalore

**Ref:-** 1. Letter No. AEE/S1/AET/13-14/1991 dt:17.10.13.


\*\*\*\*\*

With reference to the above, 'No Objection Certificate' from Jayanagar Division, BESCOM is hereby issued for the proposed M.S Building to an extent of 250KVA in favour of Sri. M.S.Sridhar, M/s Shravanee Sumo, No.20, 39<sup>th</sup> Cross, 8<sup>th</sup> Block, Jayanagar, Bangalore. Subject to the following conditions:

1. *Power supply to your proposed M.S. Building will be arranged by tapping the existing F-7 feeder from Sarakki MUSS by laying 3\*95sq.mm HTUG Cable and it is proposed to provide 1x250KVA DTC with 20D+1VL DAS compatible RMU*
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **self execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
3. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through your premises for which NOC is to be obtained from the concerned authorities.
4. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said MS building at the above address, all rules as per KERC Electricity Supply and Distribution code shall be observed.
6. Power supply shall be arranged to the said buildings based on the provisions of regulations of BESCOM as applicable at that time.

7. This "NOC" is issued only for the purpose of obtaining sanction for MS building plan from BDA/BMP/Competent authorities and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
8. The approximate load requirement of the above MS Building is **250KVA**
9. This **NOC** is valid for a period of **Two years** from the date of issue.

Yours faithfully,

  
Executive Engineer (E.L.),  
Jayanagar Division,  
BESCOM, Bangalore