



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka undertaking)

No: EE/KMLD/AEE(O)/AE/13-14/
Ph: 080-25631801
Fax: 080-25631801
E-Mail : eeadnlsouth.work@gmail.com
Encl:

Office of the,
Executive Engineer (Elec.,)
(C,O&M),Koramangala Division,
No.6, 7th Main, 80ft Road,
3rd Block, Koramangala,
Bangalore-560 034.

2869

22-7-2012

TO,

Sri Narasimhamurthy & B.K. Rama Prasad,
GPA, M/S VDB Pvt. Ltd. Reptd
by Sri Koshy Varghese,
Syno 136, Gunjur Palya,
Bangalore.

Sir,

Sub: Issue of NOC to the proposed Residential Apartment to an extent 764KW in favor of
Sri Narasimhamurthy & B.K. Rama Prasad, GPA, M/S VDB Pvt. Ltd. Reptd by Sri Koshy Varghese, Syno
136, Gunjur Palya, Bangalore.

Ref: 1. Letter No: AEE/S7/AET/3369/ 15.7.2013.


With reference to the above, "No Objection Certificate" from Koramangala Division, B'lore is hereby
issued for arranging power supply to the proposed Residential Apartment to an extent of 764KW at Syno
136, Gunjur village, Bangalore.:

Power supply to your proposed residential apartments will be arranged with the following
arrangements:

Regular Source:-

- a) It is proposed to run a new feeder from Cessna Tech Park MUSS by laying 3x400sqmm HT UG cable to a distance of 5.0km and 04nos of interposing OD'S in the route length and suitable breaker at MUSS.
- b) It is proposed to provide one RMU of 2OD + 1VL inside the applicant's premises.
- 1) you have to develop the infrastructure including the cost of 11KV lines etc, as mentioned above on Self- execution basis through a Government class-I electrical contractor by paying necessary Supervision charges to BESCOM duly observing BESCOM formalities.
- 2) If any KPTCL/ BESCOM lines are passing through the applicant's premises these shall be shifted at Your cost. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities
- 3) If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.

- 4) While applying for power supply to the above address, all rules as per KERC Electricity supply and distribution code shall be observed.
- 5) Power supply shall be arranged to the said buildings based on the provisions of regulations of BESCOM is applicable at that time
- 6) This "NOC" is issued only for the purpose of obtaining sanction plan for from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for subject to feasibility at that time.
- 7) The approximate load requirement of the above residential apartment is 764KW.
- 8) This NOC is valid for a period of Two Years from the date of issue.
- 9) For MS Residential building / apartments Solar Heaters should be provided with a capacity of 100 Liters either for individual flat or bulk solar water heater to be provided with suitable capacity which may be calculating 100 liters/ flat.
- 10) As per the above, if there is no sufficient space to provide Solar Water heater block of MS Residential/apartments should be provided with solar water heater of capacity 100 liters/ flat either individual or bulk solar water heater by calculating 100 liters/ flat for total No of flats on the top of the block
- 11) In future, if the requested load exceeds 4000 kVA, the Applicant have to provide prescribed space to establish a 66/11kV MUSS at free of cost to KPTCL.


(S.T. Shanthamallappa)
Executive Engineer, Ele.
Koramangala Division,
BESCOM, Bangalore-34

Copy to:

1. The Assistant Executive Engineer (EI), S7 Sub Division, BESCOM, HAL Airport Road, Bangalore for information.
2. AE/MP