



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.: SEE/BCS/EE(O)/AEE-3/NOC-19/14-15/

Encl:

Email: southcircle.work@gmail.com

Ph: 22230636, Fax: 22118861

Superintending Engineer, C, O&M, Bangalore
South Circle, BESCOM No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nrupathunga
Road, Bangalore-560 001.

To

M/s Shrivision Homes Pvt Ltd.,

Sy No. 35, 41, 43, 44, 45, 46, 58, 59 60 & 61,

Kasavanahalli Village,

Varthur Hobli, Bangalore.

Revised

9 DEC 2014

Sir,

Sub:- Issue of NOC for arranging power supply to an extent of **1950KVA** to the proposed **Residential & Commercial Building** in favour of M/s Shrivision Homes Pvt Ltd., Sy No. 35, 41, 43, 44, 45, 46, 58, 59 60 & 61, Kasavanahalli Village, Varthur Hobli, Bangalore.

Ref:- 1. T.O. NOC No. SEE/EE(O)/AEE-2/NOC-29/12-13/15429-31 dt: 16.01.2013
2. Ltr No. EE(E)/HSRD/AEE(O)/JE-1/5546 dt: 28.11.2014.

With reference to the above, '**No Objection Certificate**' is hereby issued for arranging power supply to the proposed **Residential & Commercial Building** to an extent of **1950KVA** at Sy No. 35, 41, 43, 44, 45, 46, 58, 59 60 & 61, Kasavanahalli Village, Varthur Hobli, Bangalore, subject to the following conditions: -

1. Power supply to your proposed total blocks - **03 Blocks with Block-1(2BF+GF+19UF's), Block-2 (2BF+GF+24UF's), Block-3 (GF+6UF's)** for Residential & Commercial Building in the total land area - **15 Acres, 9 Guntas** will be arranged with the following arrangements.

Proposals:


Regular Source:

- a. To lay 3x400Sq.mm UG cable from Shobha MUSS to the applicant premises to a distance of 3.1km by providing 3Nos. of intermediate OD's in between Shobha MUSS & applicant premises.
- b. To provide 2OD+2VL RMU inside the premises.

Alternate Source:

- a. To lay 3x400Sq.mm UG cable from Naganathapura MUSS to applicant premises to a distance of 7.0km by providing 6Nos. of intermediate OD's in between Naganathapura MUSS & applicant premises.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **self execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

3. If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. **This NOC does not apply to the premises where EHT lines are passing through the premises for which a separate NOC is to be obtained from the concerned KPTCL authorities.**
4. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said Residential & Commercial Building /various buildings at the above address, all prevailing rules of KERC at that time and Conditions of Supply shall be observed.
6. Power supply shall be arranged to the said Residential & Commercial Building based on the provisions of regulations of BESOCM as applicable at that time.
7. This "NOC" is issued only for the purpose of obtaining sanction plan for Residential & Commercial Building from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
8. The approximate load requirement of the above Residential & Commercial Building is 1950KVA.
17. An undertaking shall be given to spare the land measuring 50mtr x 60mtr to KPTCL / BESCOM at free of cost for establishing 66/11KV sub station.
9. This NOC is valid for a period of **Two year** from the date of issue.

Yours faithfully,

(Mohan Kalluraya N)
Superintending Engineer (EL.),
Bangalore Circle (South), BESCOM,
Bangalore