



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No.: SEE/BCS/EE(O)/JE-3/NOC-38/16-17/

Encl:

Email: sesouthcircle.work@gmail.com

Ph: 22230636, Fax: 22118861

Superintending Engineer, C, O&M, Bangalore

South Circle, BESCOM No. 14/3, 3rd Floor,

Maharshi Aravinda Bhavan, Nrupathunga

Road, Bangalore-560 001.

To

Smt. Kamalamma & Others,
GPA M/s. Vajram Holdings Pvt Ltd,
Rept by Vajram Pavan Kumar,
Sy No. 57/4, Old Sy No. 57/2,
Devarabisanahalli Village, Bangaluru.

28 NOV 2016

Sir,

Sub:- Issue of NOC for arranging power supply to an extent of **1879KVA** to the proposed **Residential Apartment & Commercial Building** in favour of Smt. Kamalamma & Others, GPA M/s. Vajram Holdings Pvt Ltd., Rept by Vajram Pavan Kumar, Sy No. 57/4, old Sy No. 57/2, Devarabisanahalli Village, Bangaluru in Marathahalli O&M Unit of S-7 S/D.

Ref:- Ltr No. EE/KMLD/AEE(O)/AE/16-17/3805 dtd 25.11.2016.

With reference to the above, '**No Objection Certificate**' is hereby issued for arranging power supply to the proposed **Residential Apartment & Commercial Building** to an extent of **1879KVA** at **Sy No. 57/4, old Sy No. 57/2, Devarabisanahalli Village, Bangaluru**, subject to the following conditions: -

1. Power supply to your proposed **total blocks - 01 Block with 2BF+GF+ 12UF's+Terrace Floor for Residential Apartment & Commercial Building in the total land area - 10521.83Sq.mtr** will be arranged with the following arrangements.

Proposals:

Regular Source:

- a. To draw new feeder from Vikas Telecom MUSS (yet be commissioned) by laying 3x400Sq.mm HTUG cable to a distance of 3.2km by providing 11KV Station breaker inside the MUSS.
- b. To provide one interposing OD.

Alternate Source:

- c. To draw new feeder from Pritech MUSS by laying 3x400Sq.mm HTUG cable to a distance of 1.6km by providing 11KV Station breaker inside the MUSS.
 - d. To provide 3way RMU inside the applicant premises.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **self execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

..2)

3. If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. **This NOC does not apply to the premises where EHT lines are passing through the premises for which a separate NOC is to be obtained from the concerned KPTCL authorities.**
4. The applicant has to maintain the following corridor width, based on the voltage of EHV line, if any EHT line passes through the layout.

66KV	220KV	400KV
18 mtrs (9mtr on either side from the center of the line)	35 mtrs (17.5 mtrs on either side from the center of the line)	52 mtrs (26 mtrs on either side from the center of the line)

5. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
6. While applying for power supply to the said **Residential Apartment & Commercial Building** /various buildings at the above address, all prevailing rules of KERC at that time and Conditions of Supply shall be observed.
7. BESCOM will not be held responsible for any liability arising from the issue of NOC.
8. Power supply shall be arranged to the said **Residential Apartment & Commercial Building** based on the provisions of regulations of BESOCM as applicable at that time.
9. This "**NOC**" is issued only for the purpose of obtaining sanction plan for **Residential Apartment & Commercial Building (10521.83Sq.mtr)** from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
10. The approximate load requirement of the above **Residential Apartment & Commercial Building** is **1879KVA**.
11. If the requisitioned load is more than 7500KVA, the applicant has to establish 66/11KV substation inside the premises under self execution.
12. This **NOC** is valid for a period of **Two year** from the date of issue.

Yours faithfully,


(Vishwanath Naik)

Superintending Engineer (El.),
Bangalore Circle (South), BESCOM,
Bangalore

Copy to:

1. The Ex. Engineer (El.) (C, O&M), **Koramangala Divn**, BESCOM, B'lore along with the entire file for infn.
2. The Asst. Ex. Engineer, Elec., **S-7** Sub-Division, BESCOM, Bangalore for infn.
3. R&R to JE-3/F-NOC/MF.