

Bescom

Estimate No. MB-128 dated 03/03/2017 Estimate for Temporary

power supply is an extent of 8KW HP/KW Construction purpose for a period

28 days of Sri/Smt. Dr. ARDRA Kumari No 38

22/3 D.B. hally Mahathma Gandhi Road Uppanahy

Sl. No.	Particulars	Unit	Qty.	Single Phase	Three Phase
1.	S/Ph, 3Ph, Motor			1,010-00	4,900-00
2.	P & B cutout etc., (3% on above)			50-00	147-00
3.	Cost of the labour			50-00	100-00
4.	Employees cost at 20% (item No. 1 and 2)			208-00	1,009-00
5.	Transportation charges			25-00	25-00
6.	Misc. Materials			12-00	10-00
7.	Contingencies at 5% on item 1 & 3			65-00	309-00
8.	Total cost of the estimate			1,400-00	6,500-00
9.	Service charges at 20% on item No. 8			140-00	1,300-00
10.	Cost of the returnable materials credit			1,010-00	4,900-00
11.	Net cost of the estimate			390-00	1,600-00

RKNO: C8TP. 7695

10/3/17

CERTIFICATE

Certified that I, have inspected the spot personally and prepared the estimate as per the current schedule of rates for most economical and safe way execution of work.

Report : The transformer : 250kVA KVA at D.B. hally

can take up this additional load 100kVA

0 Hs 11/10/17

Next 2 Pals 10/11/17

1771-44917

TR-85/13R

pot. A Au 1.1 1000/175025

M. Padaratho
Sanction Officer
Bescom, O & M Unit

SUB - DIVISION OFFICE USE

1. Sanctioned Load 8KW H.P.

2. Period 28 days.

3. Deposit held Rs. 22020 / 330 944 7662816 Vide Receipt No. 100/-30944767406 / 10/3/17

4. W.O.No. (to draw materials : 22.731) NEEL 18/17 18 / 227317 / U- 37464 / 10/3

W.O. No. (returnable materials) : 74 511/390 Dt. 10/3/17