

2



**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**  
(WHOLLY OWNED GOVERNMENT OF KARNATAKA UNDERTAKING)

NO:SEE/BEC-885/EE(O)/AEE-1/14-15/  
Encl:

/10711-13

Office of the  
Superintending Engineer (EI)  
East Circle, # 12, Curve Circle,  
Tasker Town, Shivajinagar,  
Bangalore -560051  
Date :

Phone/Fax-080-22863422  
Email Id: seeast@bescom.co.in

To,

M/s. Marvel Infrabuild Pvt Ltd., & Others  
Sy. No. 213/3, Veeraswamy Reddy Colony,  
Near WGS School, Channasandra Main Road,  
Kadugode, Bangaore -560067.

Sir,

Sub: Issue of NOC for arranging power supply to an extent of **1360KVA** to your proposed residential multistoried building project at Sy. No. 139, Channasandra Village, Bidarahalli Hobli, Bangaore East Taluk, in E4 sub-division-Reg.,

Ref: Executive Engineer (EI), Indiranagar Division office letter No. EEE/INR /AEE(O)/AET-1/7008 dt.16.01.2015.


\*\*\*\*\*

With reference to the above, '**No Objection Certificate**' from, BESCOM Bangalore East Circle is hereby issued for arranging power supply to an extent of **1360KVA** for the proposed residential multistoried building project at Sy. No. 139, Channasandra Village, Bidarahalli Hobli, Bangaore East Taluk, as per Clause 30.11 Conditions of Supply of Electricity of Distribution Licensees in the State of Karnataka which is in force and its amendments from time to time subject to the following conditions:

1. Power supply to your Residential Building will be arranged with the following arrangements.
  - a. **Regular Source**
    - It is proposed to extend New 11KV feeder from Kadugodi MUSS by installing associated 11KV breaker along with allied equipment's inside the substation and extend 11KV line using 3x400sq.mm XLPE UG Cable to a distance of 4KMs.
  - b. **Alternate Source:**
    - It is proposed to Link F2 11KV feeder of Kadugodi MUSS by extending 11KV line using 3x400sq.mm XLPE UG Cable to a distance of 0.5KM.
2. You have to develop the necessary infrastructure such as extension of 11KV lines, installing breakers/isolators at substation, distribution transformers and other allied works as mentioned above at your own cost on self-execution works basis through appropriate Licensed Electrical Contractor (L.E.C.) having valid License issued / recognized by the Government of Karnataka by paying necessary supervision charges and duly observing BESCOM formalities.

3. If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. This NOC does not apply to the premises where EH lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
4. If any installation existing in the said premises the same shall be surrendered after clearing all arrears before taking up infrastructure work.
5. While applying for power supply to the said Residential Building at the above address, all rules as per KERC Electricity Supply and Distribution code in force shall be observed.
6. Power supply shall be arranged to the said Residential Building based on the provisions of regulations of BESCOM which are applicable at that time.
7. This "NOC" is issued only for the purpose of obtaining sanction plan for Residential Building from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for subject to feasibility at that time.
8. The Approximate load requirement of the above Residential Building is 1360KVA
9. **This NOC is valid for a period of Two years from the date of issue.**

Yours faithfully

  
(Hanumantharayappa)  
Superintending Engineer (El)  
Bangalore East Circle.