1368

No. CHE/A-0064/BP(WS)/AP of 2014-2015

13 1 JUL 2014.

0BMPP-8028-2010-11-2,000 Forms (4 Pages F/B)

	346 उपप्रमुख अभियता हमारत (पस्ताव) घ.इ. दीन	EC-48
Forn	महापालका झारत, सा विग, संस्कृती कामलेक्स, 1 ए जुट डी.पी. रोड, सेंट लॉरेंट्सी शक्तिक्से, ing please quote No.	IS ISSUED SUBJECT ISIONS OF URBAN LAND REGULATIONS ACT 1876

Intimation of Disapproval under Section 346 of the Mumbai Municipal Corporation Act, as amended upto date

No. CHE/A-0064/BP(WS)/AP of 2014-2015

MEMORANDUM

Owners: Shri Dinesh P. Hingoo & Others

With reference to your Notice 337, letter	No	_dated
20 and delivered on	20	and the
plans, Sections Specifications and Description a	nd further	particulars
and details of your buildings at Proposed	Redevel	opment of
building on plot bearing C.T.S. No. 521, 52	1/1 to 4,	of Village
Pahadi Goregaon, Plot No. 249, at Jawahar	Nagar R	oad No.15,
Goregaon (West), furnished to me under	your le	tter, dated
20 I have to inform	you tha	t I cannot
approval of the building or work proposed to be	erected o	or executed,
and I therefore hereby formally intimate to you	under sec	ction 346 of
the Mumbai Municipal Corporation Act as am	ended upt	o date, my
disapproval by thereof reasons:-		
	-	

A. CONDITIONS TO BE COMPLIED WITH BEFORE STARTING THE WORK / BEFORE PLINTH C.C.

- 1. That the C.C. under Sec. 44\69 (1) (a) of the M.R.T.P. Act will not be obtained before starting the proposed work.
- 2. That the compound wall is not constructed on all sides of the plot clear of the road widening line with foundation below level of bottom of road side drain without obstructing the flow of rain water from the adjoining holding to prove possession of holding before starting the work as per D.C.Reg.No.38(27).
- 3. That the low lying plot will not be filled up to a reduced level of at least 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders etc. and will not be levelled, rolled, consolidated and sloped towards road side, before starting the work.