



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಂಪೂರ್ಣ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಪತ್ರ ಸಂಖ್ಯೆ: ಅಇಂ(ವಿ)/ಬೆಗ್ರಾವ್ಯ/ಕಾಂ(ಕ)/ಸಕಾಂ-1/17-18/

6101-02

ಉಗ್ರತೆ:

ಅಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್ (ವಿ,) ರವರ ಕಛೇರಿ,
ಬೆಂಗಳೂರು ಗ್ರಾಮೀಣ ವೃತ್ತ, ಟಿ.ಟಿ.ಎಂ.ಸಿ ಕಟ್ಟಡ,
ಮೈಸೂರು ರಸ್ತೆ, ಕೆಂಗೇರಿ, ಬೆಂಗಳೂರು - 560060
ದೂರವಾಣಿ: 28482374 ಮೊ: 94482 79007

ಈ ಮೇಲ್-sebrc@bescom.co.in

ದಿನಾಂಕ:

19/03/2018

To

M/s ASSETZ Premium Holding Pvt Ltd,
Embassy Icon Annex, 2nd Floor,
Infantry road, Bangalore- 5600101.

Sir,

Sub: Issue of NO Objection Certificate (NOC) for arranging power supply to an extent of 1890 KVA for proposed Residential Row houses in favour of M/s ASSETZ Premium Holding Pvt Ltd, Sy No. 16/2, 8/1, 9/1, 9/2, 9/3, 9/4, 17 and 7 Hosahalli village, Jala Hobli, Bangalore North Taluk in Vidyanagara sub division.


Ref: EEE/HKTD/AEE(O)/AE-1/2017-18/8337-38 dated 17.03.2018.

With reference to the above, '**No Objection Certificate**' (NOC) is hereby issued for arranging power supply to an extent of 1890 KVA for proposed Residential Row houses in favour of M/s ASSETZ Premium Holding Pvt Ltd, Sy No. 16/2, 8/1, 9/1, 9/2, 9/3, 9/4, 17 and 7 Hosahalli village, Jala Hobli, Bangalore North Taluk in Vidyanagara sub division, Subject to the following conditions:

1. Power supply to your proposed ROW houses will be arranged from proposed New Feeder from existing 66/11KV Vidyanagara MUSS by providing 3*400 Sqmm HTUG Cable to a distance of 2.8 KM. Proposed New Feeder from existing 66/11KV Begur MUSS by providing 3*400 Sqmm HTUG Cable is considered as alternate feeder.
2. You have to develop the infrastructure of providing new Feeders and 11KV lines/UG cable on **self execution** basis through a Government Class-I Electrical contractor by paying necessary supervision charges to BESCOM duly observing formalities.
3. The BESCOM lines which are passing through the premises shall be shifted at your cost after payment of supervision charges.
4. This NOC does not apply to the premises where EHT lines are passing through the premises for which NCC is to be obtained from the concerned authorities.

5. The existing installations **if any** shall be surrendered by clearing all the arrears before taking up infrastructure work in the premises.
6. While applying for power supply to the said Building at the above address, all rules as per "KERC Conditions of Supply of Electricity in the State of Karnataka" shall be observed.
7. Power supply shall be arranged to the said Building based on the provisions of regulations of BESOCM is applicable at that time.
8. This "**NOC**" is issued as requested by you and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
9. The approximate load requirement of the above **Row Houses** is **1890 KVA under LT category.**
10. Processing charges Rs. 34200.00 collected vide Rt No. 20180000063 dated 04.01.2018.
11. 18% GST Rs. 6,156.00 collected vide Rt No. 12003, Book No.121 dated 17.03.2018.
12. This **NOC** is valid for a period of **Two years** from the date of issue.

Yours faithfully,


**Superintending Engineer (El.),
Bangalore Rural Circle, BESCOM,
Mysore Road, Kengeri, Bangalore**

Copy to :

The Executive. Engineer (El.) (C, O&M), Hosakote Division, BESCOM, Hosakote for information