



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.: EE/HSRD/JE-1/ 1914
Encl:

Office Of
Executive Engineer Elec(C,O&M)
HSR Layout Division, BESCOM,
17th cross, 24th main, HSR 2nd sector,
Bangalore-560102.

Date: 26 JUN 2014

To,
Sri Govindachary & K.Rukmini,
K.No. 76/44/19/14/4,
Chikkabellandur Village,
Varthur Hobli, Bangalore.

Sir,

Sub:- Issue of NOC to the proposed Residential Apartment for arranging power supply to an extent of 581KW (686KVA) in favour of Sri Govindachary & K.Rukmini, K.No. 76/44/19/14/4, Chikkabellandur Village, Varthur Hobli, Bangalore of S-11 Sub Division.

Ref:- 1) AEE(E)/S11/AE(T)/508 dt: 07.06.14 of the Assistant Executive Engineer Ele, S-11 Sub-Division, BESCOM, Bangalore.

2) Applicant ltr.Dt:29.05.2014.

With reference to the above, 'No Objection Certificate' from EE, BESCOM is hereby issued for issue of NOC to the proposed Residential Apartment for arranging power supply to an extent of 581KW (686KVA) in favour of Sri Govindachary & K.Rukmini, K.No. 76/44/19/14/4, Chikkabellandur Village, Varthur Hobli, Bangalore subject to the following conditions:


Proposals:-

Regular Source:-

- It is proposed to extend existing Overhead F10 feeder from Sulikunte MUSS by using Rabbit conductor to a distance of 0.5 Kms on existing 9mtr RCC poles by proposing intermediate poles. Also it is proposed to provide 11mtr spun pole with 3GOS system.
- It is proposed to extend 95Sqmm cable to a distance of 0.75Kmts inside the premises.
- It is proposed to provide 3X250KVA Transformer and Spun pole structure with 3way GOS system.
- 1. BESCOM will not be held responsible for any liability arising from the issue of NOC.

2. If any existing BESCOM lines are crossing the plot, the applicant shall clear them.
3. If any installations existing the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
4. While applying for power supply to the said Residential apartment at the above address all rules as per KERC Electricity supply and distribution code shall be observed.
5. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
6. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution by the applicant.
7. This 'NOC' is issued only for the purpose of obtaining sanction for the Residential Apartment plan from BDA/BBMP/BMIC/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
8. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution through class-I LEC.
9. For Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat.
10. As per the above, if there is no sufficient space to provide solar water heaters block of Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat for total no. of flats on the top of the blocks.
11. Validity of this NOC is for 2(Two) years only from the date of this letter.
12. NOC charges of Rs.5000/- X 2 paid RT No.512124528912 Dt: 02.06.2014.

Yours faithfully,


(A.N. Jayaraj)
Executive Engineer (Ele)
C, O&M, HSR Layout Division
BESCOM, Bangalore.